

240.001 - Minimum standards.

Sec. 1. Whenever a driveway is constructed within the Township, it shall be built to the following minimum standards:

1. A base of at least six inches of crushed limestone.
2. Have a culvert of at least 12 inches in diameter placed in ditch line to County specifications.
3. A driveway shall be at least ten feet in width.
4. All permits required shall be purchased from the County Road Commission, County Drain Commission, and/or the DNR.
5. Any driveway over 500 feet in length will be ten feet in width with a three foot wide crushed limestone shoulder on each side. It will also have either a turnaround at least 16 feet wide and 24 feet deep or a cul-de-sac with a 25 foot radius.
6. Any driveway over 800 feet in length will be constructed with the following requirements:
 - a. It shall be at least ten feet in width.
 - b. It shall have at least six inches of crushed limestone base.
 - c. A dedicated width of 33 feet shall be dedicated for the use as a driveway.